

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 141

Dated: 02/05/2024

It is certified that an inspection team headed by Brihaspati Yadav
 (Name of Officers with designation) from Chemist District Water Testing Lab
 (Name of Department/ Office) inspected the P.H.E.D, Siwan

(Name & Address of the school) on 02.05.24 (date of inspection) and found that the
Vigyanand Kendriya Vidyalaya (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of 1 year

Signature with Seal: [Signature] 02/05/24

Name

Assistant Engineer
P.H. Sub-Division, Siwan

Designation

Name & Address of the Office / Department :

To

Vigyanand Kendriya
Vidyalaya, Chanur, Siwan - 841227

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

[Signature]



[Signature]
Principal
Vigyanand Kendriya Vidyalaya
Chanur Siwan (Bihar)



बिहार सरकार

District Level Water Testing Laboratory:- Siwan

Address- Kachahari Campus Pani Tanki Siwan-841226 (Bihar)

TEST REPORT

Name & Address of the Customer :- Vigyanand Kendriya Vidyalaya Chanur, Siwan (BIHAR)	Date:	02.05.2024
	Sample No.	-
	Sample Description	Drinking Water
	Sampling Plan & Method	IS3025(Part-1)1987(RA 2019)
	Sample Collected On	30.04.2024
	Date of Performance (s)	02.05.2024
	Ref No.	-

Analysis Result

Sl. No.	Test Parameter	Unit	Test Method	Result	IS 10500:2012 Amd. 1&2		Remarks
					Acceptable Limit	Permissible Limit	
1	pH at 25 °C		IS 3025 (Part 11) : 2022	6.69	6.5	8.5	
2	Turbidity	NTU	IS 3025 (Part 10) : 2023	0.9	1	5	
3	Total Dissolved Solids (TDS)	mg/l	IS 3025 (Part 16) : 2023	270	500	2000	
4	Total Hardness (as CaCO ₃)	mg/l	IS 3025 (Part 21) : 2009 (RA- 2019)	185	200	600	
5	Calcium (as Ca)	mg/l	IS 3025 (Part 40) : 1991 (RA- 2019)	39.2	75	200	
6	Magnesium (as Mg)	mg/l	IS 3025 (Part 46) : 1994 (RA- 2019)	14.3	30	100	
7	Chloride (as Cl)	mg/l	IS 3025 (Part 32) : 1988 (RA- 2019)	25.5	250	1000	
8	Total Alkalinity (as CaCO ₃)	mg/l	IS 3025 (Part 23) : 1986 (RA- 2019)	188.4	200	600	



Disclaimer:-

- The report shall not be reproduced except in full, without approval of the laboratory.

Authorised Signatory:-
Name: - Sri Brihaspati Yadav
Designation: - Chemist

Keema
Principal
Vigyanand Kendriya Vidyalaya
Chanur Siwan (Bihar)

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 637

Dated: 18/5/24

It is certified that an inspection team headed by Bishal Kumar Singh(Name of Officers with designation) from Health Dept.(Name of Department/ Office) inspected the Vigyanand Kendriya vidyalaya, Chanaur, Siwan(Name & Address of the school) on 18-05-2024 (date of inspection) and found thatthe Vigyanand kendriya vidyalaya, Chanaur (Name of school) has safe drinking water facilities

for the students and members of staff of the institution and is maintaining the hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 01 yearsSignature with Seal: Name : Dr. Anil Kumar BhattDesignation : Civil Surgeon

Name & Address of the Office / Department :



Civil Surgeon Cum
Chief Medical Officer
Siwan

To

Vigyanand Kendriya vidyalaya
Chanaur, Siwan - 841227

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.


Principal
Vigyanand Kendriya Vidyalaya
Chanur Siwan (Bihar)