

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 130

Dated: 04/04/2026

It is certified that an inspection team headed by Pravin Kumar Singh
 (Name of Officers with designation) from Junior Engineer
 (Name of Department/ Office) inspected the PHED - Siwan, PHED - Siwan
 (Name & Address of the school) on (date of inspection) and found that
 the Vigyanand Kendriya Vidyalaya (Name of school) has safe drinking water facilities
 for the students and members of staff of the institution and is maintaining the hygienic sanitation
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
 The above is valid for a period of 1 year.

Signature with Seal: Sudhanu Shekhar Choudhary

Name

Designation

Name & Address of the Office / Department :

P.H. Subdivision - Siwan
 Anand Nagar, Siwan

To

Vigyanand Kendriya
Vidyalaya, Chaur, Siwan - 841227

(Name & Address of the Institution)

Assistant Engineer
P.H. Sub-Division, Siwan

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,
 translated notarized version in English be uploaded along with the original vernacular certificate as a
 single pdf.

Government of Bihar

Public Health Engineering Department

District Level Water Testing Laboratory:- Siwan

Sample Collected by School Authority:- VIGYANANAD KENDRIYAVIDYALAY CHANUR, SIWAN

Date:- 30.03.2026

SL. No.	Block	Panchyat	Village	Name of Habitation	Location of Source	Parameters														Total Coli
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	
1	Siwan	Chanaur	Chanaur	Chanaur	VIGYANANAD KENDRIYA VIDHYALAYA	7.23	0.6		198	65.3	32.1	7.2	19.2	56.9	0.20	BDL	BDL	0.19		<1.1
Desirable Limits						6.5-	5.0	-	500	200	75	30	250	0	1.0	45	200	1.0	0.01	
Permissible Limits						8.5	NR	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	

All parameters are under disrable limits

[Signature]
02/04/26

Chemist D.L.L
P.H. Division, Siwan